

**Etowah Utilities Board Sewer Pretreatment Criteria and Sewer Use Ordinance
Public Notice**

2023

<u>Pollutant</u>	Plant Protection Criteria Micrograms per Liter <u>ug/L</u>
Copper	265
Chromium III	239.75
Chromium VI	239.75
Chromium	239.75
Nickel	250
Cadmium	33.33
Lead	100
Mercury	1.04
Zinc	290
Silver	29.41
Cyanide	47.74
Toluene	214.29
Benzene	13.04
1,1,1-Trichloroethane	250
Ethybenzene	40
Carbon Tetrachloride	1500
Chloroform	223.68
Tetrachloroethylene	138.89
Trichlorethylene	100
1,2 Transdichloroethylene	7.5
Methylene chloride	96.15
Phenol	454.55
Naphthalene	12.5
Bis(2-ethyl hexyl) Phthalate	Report
Butyl benzyl Phthalate	Report
Di-n-butyl Phthalate	Report
Diethyl Phthalate	Report
Total Phthalate	169.74
Dibenzo (a,h) anthracene	1.6
Ammonia	21739

Etowah Utilities Board Sewer Pretreatment Criteria and Sewer Use Ordinance

Public Notice

2023

<u>Pollutant</u>	Plant Local Limits	Plant Local Limits
	Monthly Average	Daily Maximum
	<u>mg/l</u>	<u>mg/l</u>
Copper	1.62	2.43
Chromium III	1.52	2.28
Chromium VI	1.52	2.28
Chromium	1.46	2.2
Nickel	1.58	2.37
Cadmium	0.209	0.313
Lead	0.631	0.946
Mercury	0.006	0.009
Zinc	1.37	2.04
Silver	0.184	0.276
Cyanide	0.289	0.434
Toluene	1.35	2.03
Benzene	0.08	0.12
1,1,1-Trichloroethane	1.58	2.37
Ethybenzene	0.251	0.377
Carbon Tetrachloride	9.526	14.29
Chloroform	1.361	2.04
Tetrachloroethylene	0.879	1.31
Trichlorethylene	0.632	0.948
1,2 Transdichloroethylen	0.044	0.067
Methylene chloride	0.597	0.895
Phenol	2.77	4.16
Naphthalene	0.076	0.115
Bis(2-ethyl hexyl) Phthalate	Report	Report
Butyl benzyl Phthalate	Report	Report
Di-n-butyl Phthalate	Report	Report
Diethyl Phthalate	Report	Report
Total Phthalate	1.02	1.54
Dibenzo (a,h) anthracene	0.0016	0.0016
Ammonia	35.7	53.5